## Town of Herndon, Virginia Building Inspections Section Rental Inspection Program Inspection Check List

Pass	<u>Fail</u>	Inspection energy 250
		Hot Water Heater: Check to ensure temperature and pressure relief valve is piped down approximately 6 to 8 inches from floor level or piped into sump pump pit or other approved termination. IPMC 505.4
		<u>Washer/Dryer</u> : (If Provided) Check the hookups and turn them on a short cycle to ensure there are no leaks and they are in working order.
		<u>Electrical Panel Box</u> : Check for tripped breakers, missing spacers or breakers providing access to the interior buss bar. IPMC 604.1
		<u>Furnace</u> : Forced air, heat pump or other forced air type unit, check for filter, if visible, is it clean; if gas fired, check condition or flue pipe for holes, rust, is connection tight, clearance to combustible materials usually 18 inches on single wall flue. IPMC 602.3
		Hot Water Boiler: may provide domestic hot water in addition to heat, boiler circulates hot water through a system of piping and radiators and baseboard heating units. Look for a backflow prevention device, temperature and pressure relief valve it must also be piped down to floor level. IPMC 505.4
		<u>Rooms on all floors</u> : Check perimeter of room (floors/ceiling) for water damage, stains or suspected mold, check electrical outlets quantity and use your tester on random outlets.
		<b>Basement</b> : Check for egress window in basement. Bathroom/Powder Room-Flush toilets, run water in bathroom lavatories (basin), check for hot water at faucet, check under the vanity cabinet for any water leaks or signs of previous water leaks. IPMC 702.4
		Basement: Check foundation walls for cracks, breaks, and plumbing. IPMC 305.1
		<u>Bathroom/Powder Room:</u> Check bathtub/shower tiles for loose tiles and proper caulking at wall and tub as well as where the tub meets the floor. IPMC 305.1
		Bathroom/Powder Room: Check floors to ensure they are impervious to water and have no loose tiles. IPMC 305.1
		<u>Smoke Detectors</u> : Check smoke detectors on all floors and in all bedrooms. Note: If original equipment was hard-wired, they must remain hard-wired. A smoke detector must be on all floors or wings of the house. IPMC 704.2
		<u>All Rooms:</u> Check to ensure that all switch plates and duplex outlet covers are installed, check for open (exposed wires) electrical junction boxes. IPMC 605.2
		All Rooms: Check for holes in walls, floors, and ceilings. IPMC 305.1
		<u>Windows:</u> Check windows to ensure locks are on all first floor windows (6 ft. from ground 304.18.2) and window functions properly. IPMC 304.13.2
		Windows: Ensure window screens are in place and free of holes. IPMC 304.14
		Sprinklers: If the house is sprinklered check sprinkler heads for clearance requirements and ensure that no heads are painted or damaged. VUSBC (F) 903.1
		Kitchen: Run water in sink and check for leaks under the sink. Check garbage disposal for operation. IPMC 504.1
		<u>Kitchen:</u> Check inside stove to ensure it is clean and sanitary. Turn on stove and burners to ensure they are in working order.
		Kitchen: Look inside dishwasher to ensure it is clean and sanitary. Turn on dishwasher to ensure it is working properly.
		Kitchen: Look inside cabinet doors for signs of roach infestation and ensure they are clean and sanitary.
		Kitchen: Look inside refrigerator (if provided) for clean sanitary conditions free of odors.
		Stairways (inside/outside): Check to ensure handrails are in place if there are more than four risers. IPMC 304.10
		Fireplaces: Check for condition, has it been used? If so recommend chimney cleaning to landlord
		Exterior: Check to ensure that gutters and downspouts are not crushed or clogged and are free of overhanging branches. Since it is hard to determine the condition of a gutter from the ground look for plant/weed growth. Splash blocks should be in place at the terminations of the downspout. Look for green discoloration on siding, a sign that gutters and downspouts are not functional. Look for large areas of moss growth near foundation wall, this may indicate standing water. Look for areas where topsoil is missing exposing stones/pebbles. IPMC 304.7.
		Exterior: Ensure that globes are on all exterior light fixtures. IPMC 605.3
		Exterior: Ensure there are no holes in the exterior that would allow nuisance animals entry. Check especially at roof line. IPMC 304.6
		Exterior: Ensure there is no cracking or peeling paint IPMC 304.2
		Exterior: Visually look at roof covering for signs of deterioration. (note any clawing shingles or missing shingles) IPMC 304.7
		Exterior: Check fences and/or gates to ensure they are structurally sound and hardware is in place on all gates. IPMC 304.2
		Exterior: Ensure that sliding doors work properly and screen slider is secure. IPMC 304.15
		Exterior: If the house has a deck, check it to ensure it has proper railings and is structurally sound. IPMC 304.10
		Exterior: Check sidewalks/steps for tripping hazards. IPMC 302.3
		Exterior: Check foundation walls for cracks, breaks, and plumb. IPMC 304.5